

# Certificate of Approval

This certificate confirms that the company below complies with the following standard(s):

<i>Company Name</i>	<b>Majestic Fire Inc</b>	<i>Client ID</i>	<b>101445</b>
<i>Company Other Name</i>		<i>Type of Certification</i>	<b>Product Certification; System 5</b>
<i>Certification Standard</i>	<b>AS/NZS 1841.4-2007 : Portable fire extinguishers - Specific requirements for foam type extinguishers</b>		
<i>Scheme</i>	<b>Global-Mark Product Conformance Scheme</b>		
<i>Certification Review Date</i>	<b>16/04/2021</b>	<i>Certification Expiry Date</i>	<b>23/03/2026</b>
<i>Certificate Issue Date</i>	<b>26/05/2011</b>	<i>Certificate Last Update Date</i>	<b>4/06/2021</b>

**APPROVED COMPANY/SITE ADDRESS(ES):**

**4570 Van Nuys Boulevard #257 Sherman Oaks California 91403 United States**

This certification remains valid until the above mentioned expiry date and subject to the organisation's continued compliance with the certification standard, and Global-Mark's Terms and Conditions. This Certificate of Approval remains the property of Global-Mark Pty Ltd, Company Number: ACN.108-087-654. The use of the Accreditation Mark indicates accreditation by the Joint Accreditation System of Australia and New Zealand in respect to those activities covered by JAS-ANZ accreditation. Refer to [www.jas-anz.org/register](http://www.jas-anz.org/register) for verification.



**Certification Manager**



Unique Certificate Code: 9F3A8C0C90A2D474CA2586B90021A3D7

Global-Mark Pty Ltd, 407, 32 Delhi Road, North Ryde NSW 2113, Australia - Copyright 2005



Global-Mark.com.au®



WWW.JAS-ANZ.ORG/REGISTER



Model(s) on which the Global-Mark logo may be applied by the certificate holder as a declaration of compliance by the certificate holder:  
*In placing the authorised mark on the product, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the expertise of external bodies (laboratories, and technical experts).*

Model Identification	Model Name	Brand Name	Product Description / Attributes	Date Approved
203001	9.0L Foam	FirstRESPONSE	Size: 9.0L, Rating: 3A:40B FERN: 1445.4-01	05/02/2018
FFA90F	FFAU	FFAU	Size: 9.0L, Rating: 3A:40B FERN: 1445.4-01	26/05/2011

**Comments:**

Listed fire extinguisher models are constructed to AS/NZS1841.1 Portable fire extinguishers, Part 1 - General requirements standard requirements.

End of the document



**Certification Manager**